

**Adirondack Environmental Services, Inc**

Date: 30-Aug-22

**CLIENT:** Converse Laboratories, Inc.  
**Project:** Chlorination Byproducts Testing  
 Southside Water

**LabWork Order:** 220812062  
**PO#:** AD22-1094

**Lab SampleID:** 220812062-001  
**Client Sample ID:** House on Holcomb

**Collection Date:** 8/10/2022  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**HALOACETIC ACIDS - EPA 552.2**  
 ( Prep: E552.2 - 8/22/2022 )

Analyst: JvB

Chloroacetic acid	ND	2.0	S	µg/L	1	8/24/2022 6:41:00 PM
Dichloroacetic acid	6.1	1.0		µg/L	1	8/24/2022 6:41:00 PM
Bromoacetic acid	ND	1.0	S	µg/L	1	8/24/2022 6:41:00 PM
Trichloroacetic acid	22.4	1.0		µg/L	1	8/24/2022 6:41:00 PM
Dibromoacetic acid	ND	1.0		µg/L	1	8/24/2022 6:41:00 PM
Total Haloacetic acids	28.5	6.0		µg/L	1	8/24/2022 6:41:00 PM
Surr: 2,3-Dibromopropionic acid	107	70-130		%REC	1	8/24/2022 6:41:00 PM

**Lab SampleID:** 220812062-002  
**Client Sample ID:** Hydrant on Ives St

**Collection Date:** 8/10/2022  
**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

**PURGEABLE ORGANIC COMPOUNDS - EPA 524.2**

Analyst: SMD

Bromodichloromethane	5.4	0.5		µg/L	1	8/18/2022 4:50:00 PM
Bromoform	ND	0.5		µg/L	1	8/18/2022 4:50:00 PM
Chloroform	95.7	0.5		µg/L	1	8/18/2022 4:50:00 PM
Dibromochloromethane	ND	0.5		µg/L	1	8/18/2022 4:50:00 PM
Total Trihalomethanes	101	2.0	X	µg/L	1	8/18/2022 4:50:00 PM
Surr: 1,2-Dichlorobenzene-d4	92.9	80-117		%REC	1	8/18/2022 4:50:00 PM
Surr: 4-Bromofluorobenzene	100	80-125		%REC	1	8/18/2022 4:50:00 PM

**FORWARDED TO THE  
 DEPARTMENT OF HEALTH  
 BY CLI**

**Stage 2 TTHM Summary Sheet  
Location Running Annual Average**

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled 08/10/22  
 Date Analyzed 08/18/22

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	95.7	ND	5.4	ND	101.1

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	June- Aug. 2022	101.1
Previous	March. - May. 2022	79.6
Previous	Dec. 2021- Feb. 2022	49.5
Previous	Sept.- Nov. 2021	29.6
TTHM Locational Running Average:		65.0

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

**Notes:**  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)

## Stage 2 HAA5 Summary Sheet Location Running Annual Aveage

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled: 08/10/22  
 Date Analyzed: 08/24/22

Sample Site	HAA5 Individual Results (ug/L)						Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	Dibromoacetic acid	
Last House on Holcomb St. (EP)	ND	6.1			22.4	ND	28.5

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	June- Aug. 2022	28.5
Previous	March. - May. 2022	54.8
Previous	Dec. 2021- Feb. 2022	18.9
Previous	Sept.- Nov. 2021	80.3
HAA5 Locational Running Average:		45.6

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

Notes:  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)