



**ANALYTICAL RESULTS**

Project: L2347937  
 Pace Project No.: 70267842

Sample: HOLCOMB		Lab ID: 70267842001	Collected: 08/16/23 11:00	Received: 08/22/23 07:55	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>552.2 Haloacetic Acids</b>		Analytical Method: EPA 552.2 Preparation Method: EPA 552.2 Pace Analytical Services - Melville						
Dibromoacetic Acid	<1.0	ug/L	1.0	1	08/26/23 10:34	08/29/23 13:43	631-64-1	
Dichloroacetic Acid	3.2	ug/L	1.0	1	08/26/23 10:34	08/29/23 13:43	79-43-6	C2
Haloacetic Acids (Total)	7.8	ug/L	2.0	1	08/26/23 10:34	08/29/23 13:43		
Monobromoacetic Acid	<1.0	ug/L	1.0	1	08/26/23 10:34	08/29/23 13:43	79-08-3	
Monochloroacetic Acid	<2.0	ug/L	2.0	1	08/26/23 10:34	08/29/23 13:43	79-11-8	
Trichloroacetic Acid	4.7	ug/L	1.0	1	08/26/23 10:34	08/29/23 13:43	76-03-9	
<b>Surrogates</b>								
2,3-Dibromopropanoic Acid (S)	101	%	70-130	1	08/26/23 10:34	08/29/23 13:43	600-05-5	

**FORWARDED TO THE  
 DEPARTMENT OF HEALTH  
 BY CLI**

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**ANALYTICAL RESULTS**

Project: L2347937  
 Pace Project No.: 70267842

Sample: HYDRANT ON INVES		Lab ID: 70267842002	Collected: 08/16/23 11:30	Received: 08/22/23 07:55	Matrix: Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>524.2 MSV</b>		Analytical Method: EPA 524.2 Pace Analytical Services - Melville							
Bromodichloromethane	5.8	ug/L	0.50	1		08/29/23 04:32	75-27-4		
Bromoform	<0.50	ug/L	0.50	1		08/29/23 04:32	75-25-2		
Chloroform	94.1	ug/L	0.50	1		08/29/23 04:32	67-66-3		
Dibromochloromethane	<0.50	ug/L	0.50	1		08/29/23 04:32	124-48-1		
Total Trihalomethanes (Calc.)	99.9	ug/L	0.50	1		08/29/23 04:32			
<b>Surrogates</b>									
1,2-Dichlorobenzene-d4 (S)	104	%	70-130	1		08/29/23 04:32	2199-69-1		
4-Bromofluorobenzene (S)	95	%	70-130	1		08/29/23 04:32	460-00-4		

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

**Stage 2 HAA5 Summary Sheet  
Location Running Annual Aveage**

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled: 08/16/23  
 Date Analyzed: 08/29/23

Sample Site	HAA5 Individual Results (ug/L)					Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	
Last House on Holcomb St. (EP)	ND	3.2			4.7	7.9

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	June- Aug. 2023	7.9
Previous	March. - May. 2023	22.6
Previous	Dec. 2022- Feb. 2023	30.2
Previous	Sept.- Nov. 2022	39.3
HAA5 Locational Running Average:		25.0

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

Notes:  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)  
 LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)

## Stage 2 TTHM Summary Sheet Location Running Annual Aveage

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled 08/16/23  
 Date Analyzed 08/29/23

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	94.1	ND	5.8	ND	99.9

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	June- Aug. 2023	99.9
Previous	March. - May. 2023	57.9
Previous	Dec. 2022- Feb. 2023	26.15
Previous	Sept.- Nov. 2022	44.9
TTHM Locational Running Average:		57.2

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

**Notes: At this Site Chlorine Residual was .30 when sampled**  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)