



**ANALYTICAL RESULTS**

Project: L2368398  
 Pace Project No.: 70278404

Sample: **SOUTHSIDE WATER-HOUSE ON HOLC** Lab ID: **70278404001** Collected: 11/15/23 10:15 Received: 11/21/23 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>552.2 Haloacetic Acids</b>								
Analytical Method: EPA 552.2 Preparation Method: EPA 552.2								
Pace Analytical Services - Melville								
Dibromoacetic Acid	<1.0	ug/L	1.0	1	11/22/23 09:30	11/29/23 14:28	631-64-1	
Dichloroacetic Acid	13.6	ug/L	1.0	1	11/22/23 09:30	11/29/23 14:28	79-43-6	
Haloacetic Acids (Total)	41.9	ug/L	8.0	4	11/22/23 09:30	11/30/23 18:15		
Monobromoacetic Acid	<1.0	ug/L	1.0	1	11/22/23 09:30	11/29/23 14:28	79-08-3	
Monochloroacetic Acid	<2.0	ug/L	2.0	1	11/22/23 09:30	11/29/23 14:28	79-11-8	
Trichloroacetic Acid	28.3	ug/L	4.0	4	11/22/23 09:30	11/30/23 18:15	76-03-9	
<b>Surrogates</b>								
2,3-Dibromopropanoic Acid (S)	130	%	70-130	1	11/22/23 09:30	11/29/23 14:28	600-05-5	

FORWARDED TO THE  
 DEPARTMENT OF HEALTH  
 BY CLI

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

**Stage 2 HAA5 Summary Sheet  
Location Running Annual Aveage**

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled: 11/15/23  
 Date Analyzed: 11/22/23

Sample Site	HAA5 Individual Results (ug/L)						Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	Dibromoacetic acid	
Last House on Holcomb St. (EP)	ND	13.6			28.3	ND	41.9

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	Sept.- Nov. 2023	41.9
Previous	June- Aug. 2023	7.9
Previous	March. - May. 2023	22.6
Previous	Dec. 2022- Feb. 2023	30.2
HAA5 Locational Running Average:		25.7

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

Notes:  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)



**ANALYTICAL RESULTS**

Project: L2368398  
 Pace Project No.: 70278404

**Sample:** SOUTHSIDE WATER-HYDRANT ON IVE      **Lab ID:** 70278404002      Collected: 11/15/23 10:32      Received: 11/21/23 08:00      Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>524.2 MSV</b>		Analytical Method: EPA 524.2 Pace Analytical Services - Melville						
Bromodichloromethane	3.9	ug/L	0.50	1		11/22/23 15:15	75-27-4	
Bromoform	<0.50	ug/L	0.50	1		11/22/23 15:15	75-25-2	
Chloroform	43.7	ug/L	0.50	1		11/22/23 15:15	67-66-3	
Dibromochloromethane	<0.50	ug/L	0.50	1		11/22/23 15:15	124-48-1	
Total Trihalomethanes (Calc.)	47.7	ug/L	0.50	1		11/22/23 15:15		
<b>Surrogates</b>								
1,2-Dichlorobenzene-d4 (S)	99	%	70-130	1		11/22/23 15:15	2199-69-1	
4-Bromofluorobenzene (S)	97	%	70-130	1		11/22/23 15:15	460-00-4	

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.

## Stage 2 TTHM Summary Sheet Location Running Annual Average

PWS Name: Sothside Water Inc.  
 Contact Person: James V Lettiere Jr.  
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133  
 Date Sampled 11/15/23  
 Date Analyzed 11/30/23

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	43.7	ND	3.9	ND	47.6

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	Sept.- Nov. 2023	47.6
Previous	June- Aug. 2023	99.9
Previous	March. - May. 2023	57.9
Previous	Dec. 2022- Feb. 2023	26.15
TTHM Locational Running Average:		57.9

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES  
 Address: 800 Starbuck Ave  
Watertown Ny 13601  
Phone 315-788-8388

**Notes: At this Site Chlorine Residual was .30 when sampled**  
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)