



ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2427236

Pace Project No.: 70298550

Sample: SOUTHSIDE WATER-HOUSE- HOLCOMB Lab ID: 70298550001 Collected: 05/15/24 11:00 Received: 05/21/24 08:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
552.2 Haloacetic Acids								
Analytical Method: EPA 552.2 Preparation Method: EPA 552.2								
Pace Analytical Services - Melville								
Dibromoacetic Acid	<1.0	ug/L	1.0	1	05/24/24 07:52	05/25/24 11:32	631-64-1	
Dichloroacetic Acid	19.0	ug/L	1.0	1	05/24/24 07:52	05/25/24 11:32	79-43-6	C2
Haloacetic Acids (Total)	41.0	ug/L	2.0	1	05/24/24 07:52	05/25/24 11:32		
Monobromoacetic Acid	<1.0	ug/L	1.0	1	05/24/24 07:52	05/25/24 11:32	79-08-3	M1,R1
Monochloroacetic Acid	<2.0	ug/L	2.0	1	05/24/24 07:52	05/25/24 11:32	79-11-8	
Trichloroacetic Acid	22.0	ug/L	1.0	1	05/24/24 07:52	05/25/24 11:32	76-03-9	M1
Surrogates								
2,3-Dibromopropanoic Acid (S)	114	%	70-130	1	05/24/24 07:52	05/25/24 11:32	600-05-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

**Stage 2 HAA5 Summary Sheet
Location Running Annual Aveage**

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled: 05/15/24
 Date Analyzed: 05/25/24

Sample Site	HAA5 Individual Results (ug/L)					Total HAA5 (ug/L)	
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid		Dibromoacetic acid
Last House on Holcomb St. (EP)	ND	19			22	ND	41

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	April - June. 2024	41
Previous	Jan. 2024- March. 2024	9.7
Previous	Oct- Dec. 2023	41.9
Previous	July- Sept. 2023	7.9
HAA5 Locational Running Average:		25.1

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes:
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)



ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2427236

Pace Project No.: 70298550

Sample: SOUTHSIDE WATER-IVES Lab ID: 70298550002 Collected: 05/15/24 11:20 Received: 05/21/24 08:00 Matrix: Drinking Water
HYDRANT

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV		Analytical Method: EPA 524.2 Pace Analytical Services - Melville						
Bromodichloromethane	5.8	ug/L	0.50	1		05/22/24 16:14	75-27-4	
Bromoform	<0.50	ug/L	0.50	1		05/22/24 16:14	75-25-2	
Chloroform	52.5	ug/L	0.50	1		05/22/24 16:14	67-66-3	
Dibromochloromethane	<0.50	ug/L	0.50	1		05/22/24 16:14	124-48-1	
Total Trihalomethanes (Calc.)	58.3	ug/L	0.50	1		05/22/24 16:14		
Surrogates								
1,2-Dichlorobenzene-d4 (S)	100	%	70-130	1		05/22/24 16:14	2199-69-1	
4-Bromofluorobenzene (S)	104	%	70-130	1		05/22/24 16:14	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Stage 2 TTHM Summary Sheet Location Running Annual Average

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled 05/15/24
 Date Analyzed 05/22/24

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	52.5	ND	5.8	ND	58.3

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	April - June. 2024	58.3
Previous	Jan. 2024- March. 2024	40.9
Previous	Oct- Dec. 2023	47.6
Previous	July- Sept. 2023	99.9
TTHM Locational Running Average:		61.7

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes: At this Site Chlorine Residual was .30 when sampled
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)