




ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2446431
 Pace Project No.: 70309850

Sample: SOUTHSIDE WATER USERS HOLCOMB Lab ID: 70309850001 Collected: 08/14/24 12:20 Received: 08/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
552.2 Haloacetic Acids		Analytical Method: EPA 552.2 Preparation Method: EPA 552.2 Pace Analytical Services - Melville						
Dibromoacetic Acid	<1.0	ug/L	1.0	1	08/28/24 16:43	08/31/24 09:46	631-64-1	
Dichloroacetic Acid	17.8	ug/L	1.0	1	08/28/24 16:43	08/31/24 09:46	79-43-6	
Haloacetic Acids (Total)	45.3	ug/L	2.0	1	08/28/24 16:43	08/31/24 09:46		
Monobromoacetic Acid	<1.0	ug/L	1.0	1	08/28/24 16:43	08/31/24 09:46	79-08-3	
Monochloroacetic Acid	<2.0	ug/L	2.0	1	08/28/24 16:43	08/31/24 09:46	79-11-8	
Trichloroacetic Acid	27.6	ug/L	1.0	1	08/28/24 16:43	08/31/24 09:46	76-03-9	
Surrogates								
2,3-Dibromopropanoic Acid (S)	80	%	70-130	1	08/28/24 16:43	08/31/24 09:46	600-05-5	



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

**Stage 2 HAA5 Summary Sheet
Location Running Annual Aveage**

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled 08/15/24
 Date Analyzed 08/28/24

Sample Site	HAA5 Individual Results (ug/L)						Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	Dibromoacetic acid	
Last House on Holcomb St. (EP)	ND	17.8			27.6	ND	45.4

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	July- Sept. 2024	45.4
Previous	April - June. 2024	41
Previous	Jan. 2024- March. 2024	9.7
Previous	Oct- Dec. 2023	41.9
HAA5 Locational Running Average:		34.5

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes:
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)



ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2446431
 Pace Project No.: 70309850

Sample: SOUTHSIDE WATER Lab ID: 70309850002 Collected: 08/14/24 12:05 Received: 08/20/24 07:00 Matrix: Drinking Water
 USERS HYD. ON

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV		Analytical Method: EPA 524.2 Pace Analytical Services - Melville						
Bromodichloromethane	6.5	ug/L	0.50	1		08/27/24 02:03	75-27-4	
Bromoform	<0.50	ug/L	0.50	1		08/27/24 02:03	75-25-2	
Chloroform	94.2	ug/L	0.50	1		08/27/24 02:03	67-66-3	
Dibromochloromethane	<0.50	ug/L	0.50	1		08/27/24 02:03	124-48-1	
Total Trihalomethanes (Calc.)	101	ug/L	0.50	1		08/27/24 02:03		
Surrogates								
1,2-Dichlorobenzene-d4 (S)	99	%	70-130	1		08/27/24 02:03	2199-69-1	
4-Bromofluorobenzene (S)	106	%	70-130	1		08/27/24 02:03	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.

Stage 2 TTHM Summary Sheet Location Running Annual Aveage

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled 08/14/24
 Date Analyzed 08/27/24

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	94.2	ND	6.5	ND	100.7

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	July- Sept. 2024	100.7
Previous	April - June. 2024	40.9
Previous	Jan. 2024- March. 2024	47.6
Previous	Oct- Dec. 2023	99.9
TTHM Locational Running Average:		72.3

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes: At this Site Chlorine Residual was .30 when sampled
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)