



ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2508220

Pace Project No.: 70338445

Sample: SOUTSIDE WATER USERS Lab ID: 70338445002 Collected: 02/12/25 08:00 Received: 02/18/25 06:00 Matrix: Drinking Water
HYD ON

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
524.2 MSV		Analytical Method: EPA 524.2 Pace Analytical Services - Melville						
Bromodichloromethane	1.8	ug/L	0.50	1		02/23/25 14:36	75-27-4	
Bromoform	<0.50	ug/L	0.50	1		02/23/25 14:36	75-25-2	
Chloroform	21.6	ug/L	0.50	1		02/23/25 14:36	67-66-3	
Dibromochloromethane	<0.50	ug/L	0.50	1		02/23/25 14:36	124-48-1	
Total Trihalomethanes (Calc.)	23.4	ug/L	0.50	1		02/23/25 14:36		
Surrogates								
1,2-Dichlorobenzene-d4 (S)	96	%	70-130	1		02/23/25 14:36	2199-69-1	
4-Bromofluorobenzene (S)	97	%	70-130	1		02/23/25 14:36	460-00-4	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

Stage 2 TTHM Summary Sheet Location Running Annual Aveage

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled 02/12/25
 Date Analyzed 02/23/25

Sample Site	TTHM Individual Results (ug/L)				Total TThm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethan	
Last Hydrant on Ives St.	21.6	ND	1.8	ND	23.4

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	Jan. - March. 2025	23.4
Previous	Oct- Dec. 2024	46
Previous	July- Sept. 2024	100.7
Previous	April - June. 2024	40.9
TTHM Locational Running Average:		52.8

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes: At this Site Chlorine Residual was .30 when sampled
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)



ANALYTICAL RESULTS

Project: SOUTHSIDE WATER USERS L2508220

Pace Project No.: 70338445

Sample: SOUTSIDE WATER USERS Lab ID: 70338445001 Collected: 02/12/25 07:50 Received: 02/18/25 06:00 Matrix: Drinking Water
HOLCOMB

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
552.2 Haloacetic Acids								
Analytical Method: EPA 552.2 Preparation Method: EPA 552.2								
Pace Analytical Services - Melville								
Dibromoacetic Acid	<1.0	ug/L	1.0	1	02/25/25 16:00	02/27/25 16:11	631-64-1	
Dichloroacetic Acid	4.4	ug/L	1.0	1	02/25/25 16:00	02/27/25 16:11	79-43-6	
Haloacetic Acids (Total)	14.5	ug/L	2.0	1	02/25/25 16:00	02/27/25 16:11		
Monobromoacetic Acid	<1.0	ug/L	1.0	1	02/25/25 16:00	02/27/25 16:11	79-08-3	
Monochloroacetic Acid	<2.0	ug/L	2.0	1	02/25/25 16:00	02/27/25 16:11	79-11-8	
Trichloroacetic Acid	10.1	ug/L	1.0	1	02/25/25 16:00	02/27/25 16:11	76-03-9	
Surrogates								
2,3-Dibromopropanoic Acid (S)	103	%	70-130	1	02/25/25 16:00	02/27/25 16:11	600-05-5	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

**Stage 2 HAA5 Summary Sheet
Location Running Annual Aveage**

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled: 02/12/25
 Date Analyzed: 02/25/25

Sample Site	HAA5 Individual Results (ug/L)						Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	Dibromoacetic acid	
Last House on Holcomb St. (EP)	ND	4.4			10.1	ND	14.5

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	Jan. - March. 2025	14.5
Previous	Oct.- Dec. 2024	23.7
Previous	July- Sept. 2024	45.4
Previous	April - June 2024	41
HAA5 Locational Running Average:		31.2

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes:
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)
 LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)