

ALS Group USA, Corp.

dba ALS Environmental

Analytical Report

Client: Converse Laboratories, Inc.**Project:** Southside Water Users**Sample Matrix:** Drinking Water**Sample Name:** Hydrant on Ives**Lab Code:** R2607157-002**Service Request:** R2607157**Date Collected:** 05/14/26 10:40**Date Received:** 05/15/26 16:13**Units:** ug/L**Basis:** NA**Trihalomethanes, (GC/MS)****Analysis Method:** 524.2

Analyte Name	Result	MRL	Dil.	Date Analyzed	Q
Bromodichloromethane	4.3	0.50	1	05/19/26 21:31	
Bromoform	0.50 U	0.50	1	05/19/26 21:31	
Chloroform	48	0.50	1	05/19/26 21:31	
Dibromochloromethane	0.50 U	0.50	1	05/19/26 21:31	
Trihalomethanes, Total	52	2.0	1	05/19/26 21:31	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
1,2-Dichlorobenzene-d4	80	70 - 130	05/19/26 21:31	
Bromofluorobenzene	72	70 - 130	05/19/26 21:31	

Stage 2 TTHM Summary Sheet Location Running Annual Aveage

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled: 05/14/26
 Date Analyzed: 05/19/26

Sample Site	TTHM Individual Results (ug/L)				Total TTHm (ug/L)
	Chloroform	Bromoform	Bromodichloromethane	Dibromodichloromethane	
Last Hydrant on Ives St.	48		4.3		52.3

Sample Site: MRT01		
Quarter	Month/year	Total TTHM
Present	April - June. 2026	52.3
Previous	Jan. - March. 2026	14.9
Previous	Oct- Dec. 2025	42.8
Previous	July- Sept. 2025	82.1
TTHM Locational Running Average:		48.0

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total TTHM
Present		
Previous		
Previous		
Previous		
TTHM Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Notes: At this Site Chlorine Residual was .30 when sampled
 Locatin running average (LRAA)= Summation of the site specific sample results
 for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)

ALS Group USA, Corp.
dba ALS Environmental

Analytical Report

Client: Converse Laboratories, Inc.
Project: Southside Water Users
Sample Matrix: Drinking Water

Service Request: R2607157
Date Collected: 05/14/26 10:00
Date Received: 05/15/26 16:13

Sample Name: House on Holcomb
Lab Code: R2607157-001

Units: ug/L
Basis: NA

Haloacetic Acids (GC)

Analysis Method: 552.2
Prep Method: Method

Analyte Name	Result	MRL	Dil.	Date Analyzed	Date Extracted	Q
Bromoacetic Acid	1.0 U	1.0	1	05/29/26 00:24	5/28/26	
Chloroacetic Acid	2.4	2.0	1	05/29/26 00:24	5/28/26	
Dichloroacetic Acid	22 P	1.0	1	05/29/26 00:24	5/28/26	
Trichloroacetic Acid	27	1.0	1	05/29/26 00:24	5/28/26	
Dibromoacetic Acid	1.0 U	1.0	1	05/29/26 00:24	5/28/26	
Haloacetic Acids, Total	51	6.0	1	05/29/26 00:24	5/28/26	

Surrogate Name	% Rec	Control Limits	Date Analyzed	Q
2,3-Dibromopropionic Acid	83	70 - 130	05/29/26 00:24	

Stage 2 HAA5 Summary Sheet

Location Running Annual Aveage

PWS Name: Sothside Water Inc.
 Contact Person: James V Lettiere Jr.
 Contact person Phone#: cell: (315) 486-7937

PWS Numbr: NY222133
 Date Sampled 05/14/26
 Date Analyzed 05/29/26

Sample Site	HAA5 Individual Results (ug/L)						Total HAA5 (ug/L)
	Chloacetic Acid	Dichloacetic acid		Bromoacetic acid	Trichloroacetic acid	Dibromoacetic acid	
Last House on Holcomb St. (EP)	2.4	22		U	27	U	51.4

Sample Site:EP01		
Quarter	Month/year	Total HAA5
Present	April - June. 2026	51.4
Previous	Jan. - March. 2026	13.3
Previous	Oct- Dec. 2025	19.7
Previous	July- Sept. 2025	40.4
HAA5 Locational Running Average:		31.2

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Name of Laboratory: Converse Laboratories Inc./AES
 Address: 800 Starbuck Ave
Watertown Ny 13601
Phone 315-788-8388

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Sample Site:		
Quarter	Month/year	Total HAA5
Present		
Previous		
Previous		
Previous		
HAA5 Locational Running Average:		

Notes:
 Locatin running average (LRAA)= Summation of the site specific sample results for the current quarter and previous three (3) quarters, divided by four (4)

LRAA= (Present qtr.+ Previous Qtr. + Previous Qtr. + Previous Qtr.)