

Converse Laboratories Inc.
800 Starbuck Ave. Suite B101
Watertown, NY 13601

NYS Approved ELAP
ID# 10708

USPH Certified
ID# 36144

Client: Southside Water Users
16115 Heaslip Lane
Clayton, NY 13624

Report Date:
7/27/2026
*Revised Date:
7/28/2026

Laboratory Report

Sample ID: 26D09535 Sample Type: Finished, Chl.-0.74
Sample Date/Time: 7/25/2026 0848 Sample Site: 21984 Birch Lane
Date/Time Received: 7/25/2026 1019 Sampler: WRB/CLI-Doc 314

Analysis	Result	Units	Method Code	Lab ID	Date/Time/Tech Tested
Coliform, Total	NEG	100ml	SM 23-9223B	10708	7/25/2026 1027 TLE

Sample ID: 26D09536 Sample Type: Finished, Chl.-0.69
Sample Date/Time: 7/25/2026 0903 Sample Site:* 21909 Birch Lane
Date/Time Received: 7/25/2026 1019 Sampler: WRB/CLI-Doc 314

Analysis	Result	Units	Method Code	Lab ID	Date/Time/Tech Tested
Coliform, Total	POS	100ml	SM 23-9223B	10708	7/25/2026 1027 TLE
E. Coli	NEG	100ml	SM 23-9223B	10708	7/25/2026 1027 TLE

Reviewed by/Supervisor :

Kathryn Bromley

Key: 100ml - Amount of Water Tested

*Revised to correct Sample Site

**FORWARDED TO THE
DEPARTMENT OF HEALTH
BY CLI**

The information in this report is accurate to the best of our knowledge and capability.
In no event shall our liability exceed the cost of these services.
I certify that these results conform to NYS Department of Health Standards and
requirements (10 NYDDR Subpart 55-2)

Sample results are based on samples as they are received, unless sampled by CLI.
This report shall not be reproduced, copied, or used without written approval from CLI.

SATISFACTORY

Converse Laboratories Inc.
800 Starbuck Ave. Suite B101
Watertown, NY 13601

NYS Approved ELAP
ID# 10708

USPH Certified
ID# 36144

Client: Southside Water Users
16115 Heaslip Lane
Clayton, NY 13624

Report Date:
7/28/2026

Laboratory Report

Sample ID: 26D09593 Sample Type: Finished, Chl.-0.68
Sample Date/Time: 7/27/2026 1321 Sample Site: 21909 Birch Lane
Date/Time Received: 7/27/2026 1346 Sampler: WRB/CLI-Doc 314

Analysis	Result	Units	Method Code	Lab ID.	Date/Time/Tech Tested
Coliform, Total	NEG	100ml	SM 23-9223B	10708	7/27/2026 1450 KMB

Sample ID: 26D09594 Sample Type: Finished, Chl.-0.73
Sample Date/Time: 7/27/2026 1330 Sample Site: 21998 Birch Lane
Date/Time Received: 7/27/2026 1346 Sampler: WRB/CLI-Doc 314

Analysis	Result	Units	Method Code	Lab ID.	Date/Time/Tech Tested
Coliform, Total	NEG	100ml	SM 23-9223B	10708	7/27/2026 1450 KMB

Reviewed by/Supervisor :

Kathleen B. Dwyer

Key: 100ml - Amount of Water Tested

**FORWARDED TO THE
DEPARTMENT OF HEALTH
BY CLI**

The information in this report is accurate to the best of our knowledge and capability.

In no event shall our liability exceed the cost of these services.

I certify that these results conform to NYS Department of Health Standards and
requirements (10 NYDDR Subpart 55-2)

Sample results are based on samples as they are received, unless sampled by CLI.
This report shall not be reproduced, except in full, without written approval from CLI.